OMRON

Enables Conformance to SEMI S2-0200 and SEMATECH Application Guide for S2-93


Flush-mount E-stop Shroud

A22Z-EG2 Series



Recessed design provides neat appearance.

- Minimizes accidental activation, preventing operating errors.
- Does not obstruct down flow of air.
- Spacers can be used to adjust amount of protrusion.



SEMI S2-0200

12.4 All emergency off buttons should be clearly labeled as "EMO," "Emergency Off," or the equivalent and should be clearly legible from the viewing location. The label may appear on the button or on the yellow background.

SEMATECH Application Guide for SEMI S2-93

12.4.c The EMO should be located in an area not subject to accidental activation. If a button guard is installed, its diameter should be no less than 75 mm (3 inches) with the button recessed no more than 3 mm (0.125 inches) from the front of the guard, or equivalently configured to allow for palm activation.

Note: The EMERGENCY OFF legend plate is not provided in a set. Prepare separately or purchase the A22Z-3466-2.


Details	Model
Spacer not included	A22Z-EG2
Spacer included (one)	A22Z-EG21
Spacers included (two)	A22Z-EG22
EMERGENCY OFF legend plate	A22Z-3466-2


For details on Emergency Stop Switches, refer to the Safety Component Series Catalog (Y106) and Pushbutton Switches Catalog (X032).




The Switch is not included with this product


A22Z-EG2 A22Z-EG21 A22Z-EG22






Using One Spacer Using Two Spacers







Introducing New E-stop Shroud Set

The SEMI S2-compliant E-stop Shroud Set includes a SEMI S2-compliant E-stop Shroud and EMERGENCY OFF legend plate.

A22Z-EG1

For details, refer to the A22E Series and Accessories Brochure (A160-E1-01).



The E-stop Shroud Set does not include the Switch.

Note 1: The number of Spacers that can be used depends on the E-stop Shroud model, as follows:

Model	Number of Spacers
A22Z-EG2	0
A22Z-EG21	1
A22Z-EG22	2

Note 2: Tighten to a torque of 1.96 to 2.94 N \bullet m. Note 3: The allowable panel thickness is as follows: Without Spacers: t = 1.3 to 22.5 mm

Using one Spacer: t = 1.3 to 22.5 mm Using two Spacers: t = 1.3 to 2.5 mm

Note 4: The dimensions are taken from the front of the panel when a Switch is installed.

General Precautions

- The application examples in this brochure are provided for reference purposes only. Always check the functions and safety of devices and equipment before using them with this product.
- Before using the product under conditions which are not described in the brochure or applying the product to nuclear control systems, railroad systems, aviation systems, vehicles, combustion systems, medical equipment, amusement machines, safety equipment, and other systems, machines, and equipment that may have a serious influence on lives and property if used improperly, consult your OMRON representative.
- Make sure that the ratings and performance characteristics of the product are sufficient for the systems, machines, and equipment, and be sure to provide the systems, machines, and equipment with double safety mechanisms.

Authorized Distributor: